

Evidence of Performance

Air permeability, Watertightness, Resistance to wind load



Test Report

No. 11-003079-PR04

(PB-A01-02-en-01)

Client Marselli Bros Fabrications Ltd
Agios Eleftherios 201
Lacarna
7560 Pervolia
Zypern

Product Tilt and turn casement door, outward opening

Designation System designation: H6400

Performance-relevant product details Material: Aluminium profiles with thermal break

Overall dimensions (WxH) 1,025 mm x 2,180 mm

Special features Test sequence changed.
Ensure compatibility of the materials used.
Ensure durability of the materials used.

Basis

EN 14351-1:2006+A1:2010

Test standard/s:

EN 1026:2000-06
EN 1027:2000-06
EN 12046-1:2003-11
EN 12211:2000-06

Correspond/s to the national standard/s (e.g. DIN EN)

Representation



Instructions for use

The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. Observe the specifications set out by the applicable product standard.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented, in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 26 pages.

Results

Air permeability according to EN 12207:1999-11



Class 4

Watertightness according to EN 12208:1999-11



Class E1050


Resistance to wind load according to EN 12210:1999-11/AC:2002-08



Class C3 / B3

ift Rosenheim

14. Dezember 2011


Jörn Peter Lass, Dipl.-Ing. (FH)
Head of Testing Department
Building Components


Andreas Graf, Dipl.-Ing. (FH)
Operating Testing Officer
Tightness & Wind load



ift Rosenheim GmbH

Geschäftsführer:
Dipl.-Ing. (FH) Ulrich Sieberath
Dr. Jochen Peichl

Theodor-Gietl-Str. 7 - 9
D-83026 Rosenheim
Tel.: +49 (0)8031/261-0
Fax: +49 (0)8031/261-290
www.ift-rosenheim.de

Sitz: 83026 Rosenheim
AG Traunstein, HRB 14763
Sparkasse Rosenheim
Kto. 3822
BLZ 711 500 00

Notified Body Nr.: 0757
Anerkannte PUZ-Stelle: BAY 18
 DAP-FL-09/09 09
DAP-ZE-2268 00
TGA-ZM-16-93-00
TGA-ZM-16-93-60