

# Evidence of Performance

Resistance to wind load  
Watertightness  
Air permeability  
Test report  
10-001140-PB02-A01-02-en-01



Client ΚΑΤΑΣΚΕΥΕΣ ΑΛΟΥΜΙΝΙΩΝ Α/ΦΟΙ ΜΑΡΣΕΛΛΗ ΙΜΙΤΕΔ  
Marselli Bros Fabrications Ltd  
14 K. MISIAOYLI & KAVAZOGLOU

7560 PERVOLIA, LARNACA  
Zypern


## Basis

EN 14351-1 : 2006-03  
Test standards:  
EN 1026 : 2000-06  
EN 1027 : 2000-06  
EN 12211 : 2000-06

Corresponds to the national standard. (DIN EN)

Product	Tilt and turn casement door
System	MRS 6350
Overall dimensions (W x H)	1030 mm x 2180 mm
Frame material	Aluminium profiles
Special features	Tilt & Turn kit mechanism K3700G-1A-0530-1200 with Handle WD339 / A.C. Technometal Ltd

## Representation



## Instruction for use

The present test report serves to demonstrate the above characteristics of windows according to EN 14351-1:2006-03. The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. The conditions and requirements set out by EN 14351-1:2006-03 shall be observed.

## Validity

The data and results refer solely to the tested and described specimen.

The test results can be extrapolated as per EN 14351-1, under observance of Annex E 1., under the manufacturer's own responsibility.

The test does not allow any statement to be made on further characteristics of the present structure and quality, in particular the effects of weathering and ageing.

## Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

The cover sheet can be used as an abstract.

## Contents

The report contains a total of 22 pages.

## Resistance to wind load – EN 12210



Class C4

## Watertightness – EN 12208



Class 5A

## Air permeability – EN 12207



Class 4

ift Rosenheim  
11. October 2010

*Torsten Voigt*

Torsten Voigt, M.Eng., Dipl.-Ing. (FH)  
Operating Product Officer  
Certification & Surveillance Body

*Pascal Geiger*

Pascal Geiger, Dipl.-Ing. (FH)  
Operating Testing Officer  
Building Components



ift Rosenheim GmbH  
Geschäftsführer:  
Dipl.-Ing. (FH) Ulrich Sieberath  
Dr. Jochen Peichl

Theodor-Giell-Str. 7 - 9  
D-83026 Rosenheim  
Tel.: +49 (0)8031/261-0  
Fax: +49 (0)8031/261-290  
www.ift-rosenheim.de

Sitz: 83026 Rosenheim  
AG Traunstein, HRB 14763  
Sparkasse Rosenheim  
Kto. 3822  
BLZ 711 500 00

Notified Body Nr.: 0757  
Anerkannte PUZ-Stelle: BAY 18  
  
DAP-PL-0808 99  
DAP-ZE-2288 00  
TGA-ZM-16-93-00  
TGA-ZM-16-93-00